



aitex[®]
research & innovation center

REACTION TO FIRE

Applicant:

TEXTIL OLIUS, S.A.

Orient, 78-84
ES-08172 SANT CUGAT DEL VALLÈS
Barcelona

Is authorized to place the label "Classification of Reaction to Fire of Construction Products" according to the 2023AN0781.



CLASSIFICATION OF REACTION TO FIRE OF: CONSTRUCTION PRODUCTS

Nº: 23AN0781

The sample referenced as:

"A-270 IGN"

has been tested according to the standards EN ISO 11925-2:2020, EN ISO 13823:2020. The classification according to standard EN 13501-1:2018 is:

"B-s1,d0"

Date of Issue

13th of April 2023



aitex

Date: 13/04/2023 13:22:57

Digitally Signed by: DAVID MARSET GIMENO -

NIF: 21697288P

Celia Dolça
Head of Fire Behaviour lab.